



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-05-01474

Received Date: 05/11/2021
Reported Date: 06/03/2021
Sampled By: Christine Schultz
Tech Certification #:

Project/Test Address: 2020L-157.7; Anna Merritt Elementary; 389 Green St; Lockport NY 14094

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01474-001	157.7-1	04/30/2021	LIBRARY 124 SINK	2.56	06/02/2021	
21-05-01474-002	157.7-3	04/30/2021	CLASSROOM 122 SINK	7.39	06/02/2021	
21-05-01474-003	157.7-5	04/30/2021	CLASSROOM 121 SINK	4.50	06/02/2021	
21-05-01474-004	157.7-7	04/30/2021	CLASSROOM 120 SINK	14.3	06/02/2021	
21-05-01474-005	157.7-9	04/30/2021	CLASSROOM 119 SINK	3.90	06/02/2021	
21-05-01474-006	157.7-11	04/30/2021	CLASSROOM 118 SINK	5.11	06/02/2021	
21-05-01474-007	157.7-13	04/30/2021	CLASSROOM 117 SINK	7.20	06/02/2021	
21-05-01474-008	157.7-15	04/30/2021	CLASSROOM 116 SINK	2.52	06/02/2021	
21-05-01474-009	157.7-17	04/30/2021	CLASSROOM 115 SINK	5.41	06/02/2021	
21-05-01474-010	157.7-19	04/30/2021	CLASSROOM 114 SINK	<1.00	06/02/2021	
21-05-01474-011	157.7-21	04/30/2021	CLASSROOM 113 SINK	<1.00	06/02/2021	
21-05-01474-012	157.7-23	04/30/2021	CLASSROOM 112 SINK	1.24	06/02/2021	
21-05-01474-013	157.7-25	04/30/2021	CLASSROOM 111 SINK	<1.00	06/02/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-05-01474

Project/Test Address: 2020L-157.7; Anna Merritt Elementary; 389 Green St;
Lockport NY 14094

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01474-014	157.7-27	04/30/2021	CLASSROOM 110 SINK	<1.00	06/02/2021	
21-05-01474-015	157.7-29	04/30/2021	CLASSROOM 109 SINK	<1.00	06/02/2021	
21-05-01474-016	157.7-31	04/30/2021	CLASSROOM 108 SINK	8.35	06/02/2021	
21-05-01474-017	157.7-33	04/30/2021	CLASSROOM 107 SINK	3.59	06/02/2021	
21-05-01474-018	157.7-35	04/30/2021	CLASSROOM 106 SINK	2.72	06/02/2021	
21-05-01474-019	157.7-37	04/30/2021	CLASSROOM 105 SINK	2.09	06/02/2021	
21-05-01474-020	157.7-39	04/30/2021	CLASSROOM 104 SINK	11.8	06/02/2021	
21-05-01474-021	157.7-41	04/30/2021	CLASSROOM 103 SINK	2.69	06/02/2021	
21-05-01474-022	157.7-43	04/30/2021	CLASSROOM 102 SINK	8.01	06/02/2021	
21-05-01474-023	157.7-45	04/30/2021	CLASSROOM 101 SINK	19.5	06/02/2021	
21-05-01474-024	157.7-47	04/30/2021	NURSE OFFICE	10.1	06/02/2021	
21-05-01474-025	157.7-48	04/30/2021	FACULTY ROOM KITCHENETTE	7.38	06/02/2021	
21-05-01474-026	157.7-49	04/30/2021	FACULTY ROOM LAV	3.81	06/02/2021	
21-05-01474-027	157.7-50	04/30/2021	LAV OUTSIDE OF FACULTY ROOM	11.0	06/02/2021	
21-05-01474-028	157.7-51	04/30/2021	KITCHEN CENTER PREP SINK	<1.00	06/02/2021	
21-05-01474-029	157.7-52	04/30/2021	KITCHEN KETTLE FILL	3.35	06/02/2021	
21-05-01474-030	157.7-53	04/30/2021	KITCHEN 3 BAY RIGHT	1.27	06/02/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-05-01474

Project/Test Address: 2020L-157.7; Anna Merritt Elementary; 389 Green St;
Lockport NY 14094

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-157.7

Client: Lockport CSD Contact: Tim Parker

Building: Anna Merritt Elementary Location: 389 Green St, Lockport, NY 14094

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
1 157.7-1	Library 124 Sink	S	0:07
2 157.7-3	Classroom 122 Sink	S	0:09
3 157.7-5	Classroom 121 Sink	S	0:11
4 157.7-7	Classroom 120 Sink	S	0:13
5 157.7-9	Classroom 119 Sink	S	0:15
6 157.7-11	Classroom 118 Sink	S	0:17
7 157.7-13	Classroom 117 Sink	S	0:19
8 157.7-15	Classroom 116 Sink	S	0:21
9 157.7-17	Classroom 115 Sink	S	0:23
10 157.7-19	Classroom 114 Sink	S	0:25
11 157.7-21	Classroom 113 Sink	S	0:27
12 157.7-23	Classroom 112 Sink	S	0:29
13 157.7-25	Classroom 111 Sink	S	0:31
14 157.7-27	Classroom 110 Sink	S	0:33
15 157.7-29	Classroom 109 Sink	S	0:35
16 157.7-31	Classroom 108 Sink	S	0:37
17 157.7-33	Classroom 107 Sink	S	0:39
18 157.7-35	Classroom 106 Sink	S	0:41

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 4/30/2021

Relinquished By: E. Henderson Print Name Stohl Env: Eric Henderson Jr. Date: 5/5/2021

Received (Name / Lab): KT HARRIS K. Harris Date: 5-11-21 Time: 12:52 pm

Sample Login (Name / Lab): Travis Bloom / Yvonne Bloom Date: 5/11/21 8:50am

Analysis (Name / Lab): Yvonne Oee Date: 6/14/2021

QA/QC Review (Name / Lab): M. Harris Date: 6/14/21

Archived / Released: QA/QC InterLAB Use: Date:

21-05-01474



Due Date:
06/08/2021
(Tuesday)
AE



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-157.7

Client: Lockport CSD

Contact: Tim Parker

Building: Anna Merritt Elementary

Location: 389 Green St, Lockport, NY 14094

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
19	157.7-37 Classroom 105 Sink	S	0:43
20	157.7-39 Classroom 104 Sink	S	0:45
21	157.7-41 Classroom 103 Sink	S	0:47
22	157.7-43 Classroom 102 Sink	S	0:49
23	157.7-45 Classroom 101 Sink	S	0:51
24	157.7-47 Nurse Office	S	0:53
25	157.7-48 Faculty Room Kitchenette	S	0:55
26	157.7-49 Faculty Room Lav	S	0:57
27	157.7-50 Lav Outside of Faculty Room	S	0:59
28	157.7-51 Kitchen Center Prep Sink	S	1:01
29	157.7-52 Kitchen Kettle Fill	S	1:03
30	157.7-53 Kitchen 3 Bay Right	S	1:05

Notes:

Please e-mail lab results to labs@stohlenv.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 4/30/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 5/5/2021

Received (Name / Lab): ETHARRIS OKLAHOMA Date: 5-11-21 Time: 12:52 pm

Sample Login (Name / Lab): Tina Bloom / Shaw Bloom Date: 5/19/21 Time: 8:53 AM

Analysis (Name / Lab): Young Ode Date: 6/2/21 Time: 2:58 pm

QA/QC Review (Name / Lab): Muhhl Date: 6/3/21 Time: nan

Archived / Released: QA/QC InterLAB Use: Date: Time: