



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-05-01512

Received Date: 05/11/2021
Reported Date: 06/03/2021
Sampled By: Christine Schultz
Tech Certification #:

Project/Test Address: 2020L-157.1; Lockport High School; 250 Lincoln Ave; Lockport, NY 14094

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|-------------------|------------------|-----------------|--|--------------------------|---------------|--------------|
| 21-05-01512-001 | 157.1-1 | 04/27/2021 | KITCHEN EAST PREP SINK SINGLE BAY | 19.9 | 06/02/2021 | |
| 21-05-01512-002 | 157.1-2 | 04/27/2021 | KITCHEN WEST PREP SINK 2 BAY | 3.85 | 06/02/2021 | |
| 21-05-01512-003 | 157.1-3 | 04/27/2021 | KITCHEN REAR ROOM PREP SINK SINGLE BAY | 7.49 | 06/02/2021 | |
| 21-05-01512-004 | 157.1-4 | 04/27/2021 | KITCHEN NORTH PREP SINK SINGLE BAY | 67.4 | 06/02/2021 | |
| 21-05-01512-005 | 157.1-5B | 04/27/2021 | FOUNTAIN OUTSIDE 173C | <1.00 | 06/02/2021 | |
| 21-05-01512-006 | 157.1-6 | 04/27/2021 | ROOM 159B OFFICE KITCHENETTE | 2.72 | 06/02/2021 | |
| 21-05-01512-007 | 157.1-7B | 04/27/2021 | FOUNTAIN OUTSIDE ROOM 144 O | <1.00 | 06/02/2021 | |
| 21-05-01512-008 | 157.1-8 | 04/27/2021 | ROOM 144 O KITCHENETTE | 14.8 | 06/02/2021 | |
| 21-05-01512-009 | 157.1-9 | 04/27/2021 | ROOM 145 KITCHENETTE | <1.00 | 06/02/2021 | |
| 21-05-01512-010 | 157.1-10 | 04/27/2021 | FACULTY ROOM 126 F LAV | 64.7 | 06/02/2021 | |
| 21-05-01512-011 | 157.1-11B | 04/27/2021 | FOUNTAIN OUTSIDE MAIN OFFICE | <1.00 | 06/02/2021 | |
| 21-05-01512-012 | 157.1-12 | 04/27/2021 | MAIN OFFICE KITCHENETTE | 1.47 | 06/02/2021 | |
| 21-05-01512-013 | 157.1-13 | 04/27/2021 | NURSE OFFICE NORTH LAV | <1.00 | 06/02/2021 | |

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-05-01512

Project/Test Address: 2020L-157.1; Lockport High School; 250 Lincoln Ave;
Lockport, NY 14094

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|-------------------|------------------|-----------------|-----------------------------------|--------------------------|---------------|--------------|
| 21-05-01512-014 | 157.1-14 | 04/27/2021 | NURSE OFFICE SOUTH LAV | <1.00 | 06/02/2021 | |
| 21-05-01512-015 | 157.1-15B | 04/27/2021 | FOUNTAIN OUTSIDE GUIDANCE OFFICE | <1.00 | 06/02/2021 | |
| 21-05-01512-016 | 157.1-16 | 04/27/2021 | CONFERENCE ROOM 106 KITCHENETTE | <1.00 | 06/02/2021 | |
| 21-05-01512-017 | 157.1-17B | 04/27/2021 | NORTH CAFETERIA FOUNTAIN | <1.00 | 06/02/2021 | |
| 21-05-01512-018 | 157.1-18B | 04/27/2021 | CAFETERIA 170 FOUNTAIN | <1.00 | 06/02/2021 | |
| 21-05-01512-019 | 157.1-19B | 04/27/2021 | AUDITORIUM FOYER LEFT FOUNTAIN | <1.00 | 06/02/2021 | |
| 21-05-01512-020 | 157.1-20 | 04/27/2021 | GIRLS POOL COACH'S OFFICE LAV | 10.2 | 06/02/2021 | |
| 21-05-01512-021 | 157.1-21B | 04/27/2021 | POOL FOUNTAIN | <1.00 | 06/02/2021 | |
| 21-05-01512-022 | 157.1-22 | 04/27/2021 | BOYS POOL COACH'S OFFICE LAV | 12.6 | 06/02/2021 | |
| 21-05-01512-023 | 157.1-23B | 04/27/2021 | FOUNTAIN OUTSIDE ROOM 236 | <1.00 | 06/02/2021 | |
| 21-05-01512-024 | 157.1-24 | 04/27/2021 | ROOM 232 FACULTY KITCHENETTE | <1.00 | 06/02/2021 | |
| 21-05-01512-025 | 157.1-25 | 04/27/2021 | ROOM 232 FACULTY MENS LAV LEFT | <1.00 | 06/02/2021 | |
| 21-05-01512-026 | 157.1-26 | 04/27/2021 | ROOM 232 FACULTY MENS LAV RIGHT | 1.10 | 06/02/2021 | |
| 21-05-01512-027 | 157.1-27 | 04/27/2021 | ROOM 232 FACULTY LADIES LAV LEFT | 1.50 | 06/02/2021 | |
| 21-05-01512-028 | 157.1-28 | 04/27/2021 | ROOM 232 FACULTY LADIES LAV RIGHT | 1.35 | 06/02/2021 | |
| 21-05-01512-029 | 157.1-29B | 04/27/2021 | FOUNTAIN OUTSIDE 214 | <1.00 | 06/02/2021 | |
| 21-05-01512-030 | 157.1-30B | 04/27/2021 | FOUNTAIN OUTSIDE 203 | <1.00 | 06/02/2021 | |

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-05-01512

Project/Test Address: 2020L-157.1; Lockport High School; 250 Lincoln Ave;
Lockport, NY 14094

| Lab Sample Number | Client Sample ID | Collection Date | Collection Location | Concentration ug/L (ppb) | Analysis Date | Narrative ID |
|----------------------|---------------------|--------------------|---------------------|-----------------------------|------------------|-----------------|
|----------------------|---------------------|--------------------|---------------------|-----------------------------|------------------|-----------------|

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-157.1

Client: Lockport CSD Contact: Tim Parker

Building: Lockport High School Location: 250 Lincoln Ave, Lockport, NY 14094

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

| Sample # | Location | Outlet Type | Time |
|-----------|--|-------------|-------|
| 157.1-1 | Kitchen East Prep Sink (Single Bay) | S | 22:30 |
| 157.1-2 | Kitchen West Prep Sink (2 Bay) | S | 22:32 |
| 157.1-3 | Kitchen Rear Room Prep Sink (Single Bay) | S | 22:34 |
| 157.1-4 | Kitchen North Prep Sink (Single Bay) | S | 22:36 |
| 157.1-5B | Fountain Outside 173C | DFB | 22:38 |
| 157.1-6 | Room 159B Office Kitchenette | S | 22:40 |
| 157.1-7B | Fountain Outside Room 144 O | DFB | 22:42 |
| 157.1-8 | Room 144 O Kitchenette | S | 22:44 |
| 157.1-9 | Room 145 Kitchenette | S | 22:46 |
| 157.1-10 | Faculty Room 126 F Lav | S | 22:48 |
| 157.1-11B | Fountain Outside Main Office | DFB | 22:50 |
| 157.1-12 | Main Office Kitchenette | S | 22:52 |
| 157.1-13 | Nurse Office North Lav | S | 22:54 |
| 157.1-14 | Nurse Office South Lav | S | 22:56 |
| 157.1-15B | Fountain Outside Guidance Office | DFB | 22:58 |
| 157.1-16 | Conference Room 106 Kitchenette | S | 23:00 |
| 157.1-17B | North Cafeteria Fountain | DFB | 23:02 |
| 157.1-18B | Cafeteria 170 Fountain | DFB | 23:04 |

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 4/27/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 5/4/2021

Received (Name / Lab): KTHARRIS K Harris Date: 5.11.21 Time: 1:34pm

Sample Login (Name / Lab): Traci Bloom / Stohl Env Date: 5/11/21

Analysis (Name / Lab): Young Oca Date: 5/11/21

QA/QC Review (Name / Lab): Mehul Date: 5/11/21

Archived / Released: QA/QC InterLAB Use: Date:

21-05-01512



Due Date:
06/08/2021
(Tuesday)
AE



Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-157.1

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Client: Lockport CSD

Contact: Tim Parker

Building: Lockport High School

Location: 250 Lincoln Ave, Lockport, NY 14094

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

| Sample # | Location | Outlet Type | Time |
|-----------|-----------------------------------|-------------|-------|
| 157.1-19B | Auditorium Foyer Left Fountain | DFB | 23:06 |
| 157.1-20 | Girls Pool Coach's Office Lav | S | 23:08 |
| 157.1-21B | Pool Fountain | DFB | 23:10 |
| 157.1-22 | Boys Pool Coach's Office Lav | S | 23:12 |
| 157.1-23B | Fountain Outside Room 236 | DFB | 23:14 |
| 157.1-24 | Room 232 Faculty Kitchenette | S | 23:16 |
| 157.1-25 | Room 232 Faculty Mens Lav Left | S | 23:18 |
| 157.1-26 | Room 232 Faculty Mens Lav Right | S | 23:20 |
| 157.1-27 | Room 232 Faculty Ladies Lav Left | S | 23:22 |
| 157.1-28 | Room 232 Faculty Ladies Lav Right | S | 23:24 |
| 157.1-29B | Fountain Outside 214 | DFB | 23:26 |
| 157.1-30B | Fountain Outside 203 | DFB | 23:28 |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 4/27/2021

Relinquished By: E. Henderson Print Name Stohl Env: Eric Henderson Jr. Date: 5/4/2021

Received (Name / Lab): R. Harris / R. Harris Date: 5.11.21 Time: 1:34 pm

Sample Login (Name / Lab): Tina Bloom / Tina Bloom Date: 5/19/21 Time: 8:57 am

Analysis (Name / Lab): Tony O'Connell Date: 6/2/21 Time: 1:34 pm

QA/QC Review (Name / Lab): M. Miller Date: 6/3/21 Time: hmm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____