



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

**Client:** Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

**Report Number:** 21-05-01484

**Received Date:** 05/11/2021  
**Reported Date:** 06/01/2021  
**Sampled By:** Christine Schultz  
**Tech Certification #:**

**Project/Test Address:** 2020L-157.2; Emmet Belknap Intermediate School; 491 High St; Lockport, NY 14094

**Client Number:**  
33-5980

# Laboratory Results

**Fax Number:**  
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01484-001	157.2-1A	04/30/2021	FOUNTAIN OUTSIDE CLASSROOM 221	<1.00	05/28/2021	
21-05-01484-002	157.2-1B	04/30/2021	FOUNTAIN OUTSIDE CLASSROOM 221	<1.00	05/28/2021	
21-05-01484-003	157.2-2	04/30/2021	2ND FLOOR VACULTY ROOM KITCHENETTE	4.45	05/28/2021	
21-05-01484-004	157.2-3	04/30/2021	2ND FLOOR FACULTY ROOM MENS LAV	<1.00	05/28/2021	
21-05-01484-005	157.2-4	04/30/2021	2ND FLOOR FACULTY ROOM WOMENS LAV	<1.00	05/28/2021	
21-05-01484-006	157.2-5A	04/30/2021	FOUNTAIN OUTSIDE ROOM 200	<1.00	05/28/2021	
21-05-01484-007	157.2-5B	04/30/2021	FOUNTAIN OUTSIDE ROOM 200	<1.00	05/28/2021	
21-05-01484-008	157.2-6	04/30/2021	MAIN OFFICE KICHENETTE	7.05	05/28/2021	
21-05-01484-009	157.2-7	04/30/2021	MAIN OFFICE LAV	3.68	05/28/2021	
21-05-01484-010	157.2-8	04/30/2021	LIBRARY OFFICE/KITCHENETTE	11.3	05/28/2021	
21-05-01484-011	157.2-9A	04/30/2021	FOUNTAIN OUTSIDE LIBRARY GIRLS GANG LAV	<1.00	05/28/2021	
21-05-01484-012	157.2-9B	04/30/2021	FOUNTAIN OUTSIDE LIBRARY GIRLS GANG LAV	<1.00	05/28/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-05-01484

**Project/Test Address:** 2020L-157.2; Emmet Belknap Intermediate School; 491 High St; Lockport, NY 14094

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01484-013	157.2-10A	04/30/2021	FOUNTAIN OUTSIDE LIBRARY BOYS GANG LAV	<1.00	05/28/2021	
21-05-01484-014	157.2-10B	04/30/2021	FOUNTAIN OUTSIDE LIBRARY BOYS GANG LAV	<1.00	05/28/2021	
21-05-01484-015	157.2-11	04/30/2021	NURSE OFFICE MAIN	<1.00	05/28/2021	
21-05-01484-016	157.2-12	04/30/2021	NURSE OFFICE LAV	<1.00	05/28/2021	
21-05-01484-017	157.2-13A	04/30/2021	FOUNTAIN OUTSIDE 1ST FLOOR FACULTY LAVS	<1.00	05/28/2021	
21-05-01484-018	157.2-13B	04/30/2021	FOUNTAIN OUTSIDE 1ST FLOOR FACULTY LAVS	<1.00	05/28/2021	
21-05-01484-019	157.2-14	04/30/2021	1ST FLOOR FACULTY LADIES LAV	6.96	05/28/2021	
21-05-01484-020	157.2-15	04/30/2021	1ST FLOOR FACULTY MENS LAV LEFT	4.82	05/28/2021	
21-05-01484-021	157.2-16	04/30/2021	1ST FLOOR FACULTY MENS LAV RIGHT	4.88	05/28/2021	
21-05-01484-022	157.2-17	04/30/2021	FOUNTAINS OUTSIDE ROOM 112 LEFT	<1.00	05/28/2021	
21-05-01484-023	157.2-18	04/30/2021	FOUNTAINS OUTSIDE ROOM 112 RIGHT	<1.00	05/28/2021	
21-05-01484-024	157.2-19	04/30/2021	BOYS COACH'S OFFICE LAV	4.29	05/28/2021	
21-05-01484-025	157.2-20	04/30/2021	SINGLE LAV OUTSIDE ROOM B80	1.20	05/28/2021	
21-05-01484-026	157.2-21	04/30/2021	CLASSROOM B80 OFFICE WASH SINK	5.17	05/28/2021	
21-05-01484-027	157.2-22	04/30/2021	HOME EC B110 LEFT	<1.00	05/28/2021	
21-05-01484-028	157.2-23	04/30/2021	HOME EC B110 RIGHT	<1.00	05/28/2021	
21-05-01484-029	157.2-24	04/30/2021	HOME EC B90 LEFT	2.96	05/28/2021	
21-05-01484-030	157.2-25	04/30/2021	HOME EC B90 RIGHT	2.70	05/28/2021	
21-05-01484-031	157.2-26	04/30/2021	HOME EC B100 LEFT	<1.00	05/28/2021	
21-05-01484-032	157.2-27	04/30/2021	HOME EC B100 RIGHT	<1.00	05/28/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-05-01484


**Project/Test Address:** 2020L-157.2; Emmet Belknap Intermediate School; 491  
High St; Lockport, NY 14094

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01484-033	157.2-28	04/30/2021	BOYS SIDE GYM FOUNTAIN	<1.00	05/28/2021	
21-05-01484-034	157.2-29	04/30/2021	GIRLS SIDE GYM FOUNTAIN	<1.00	05/28/2021	
21-05-01484-035	157.2-30A	04/30/2021	FOUNTAIN OUTSIDE B30	<1.00	05/28/2021	
21-05-01484-036	157.2-30B	04/30/2021	FOUNTAIN OUTSIDE B30	<1.00	05/28/2021	
21-05-01484-037	157.2-32	04/30/2021	CAFETERIA FACULTY LADIES LAV	<1.00	05/28/2021	
21-05-01484-038	157.2-33	04/30/2021	CAFETERIA FACULTY MENS LAV	<1.00	05/28/2021	
21-05-01484-039	157.2-34A	04/30/2021	CAFETERIA FOUNTAIN	<1.00	05/28/2021	
21-05-01484-040	157.2-34B	04/30/2021	CAFETERIA FOUNTAIN	<1.00	05/28/2021	
21-05-01484-041	157.2-35	04/30/2021	KITCHEN DISH AREA 3 BAY RIGHT	1.53	05/28/2021	
21-05-01484-042	157.2-36	04/30/2021	KITCHEN CENTER PREP SINGLE BAY	<1.00	05/28/2021	

**Method:** EPA 200.8

**Analyst:** Anthony Dee

**Accreditation #:** NY 11714

Reviewed By Authorized Signatory: 

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



## Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-157.2

Client: Lockport CSD

Contact: Tim Parker

Building: Emmet Belknap Intermediate School

Location: 491 High St, Lockport, NY 14094

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
157.2-1A	Fountain Outside Classroom 221	DF	1:08
157.2-1B	Fountain Outside Classroom 221	DFB	1:10
157.2-2	2nd Floor Faculty Room Kitchenette	S	1:12
157.2-3	2nd Floor Faculty Room Mens Lav	S	1:14
157.2-4	2nd Floor Faculty Room Womens Lav	S	1:16
157.2-5A	Fountain Outside Room 200	DF	1:18
157.2-5B	Fountain Outside Room 200	DFB	1:20
157.2-6	Main Office Kitchenette	S	1:22
157.2-7	Main Office Lav	S	1:24
157.2-8	Library Office / Kitchenette	S	1:26
157.2-9A	Fountain Outside Library Girls Gang Lav	DF	1:28
157.2-9B	Fountain Outside Library Girls Gang Lav	DFB	1:30
157.2-10A	Fountain Outside Library Boys Gang Lav	DF	1:32
157.2-10B	Fountain Outside Library Boys Gang Lav	DFB	1:34
157.2-11	Nurse Office Main	S	1:36
157.2-12	Nurse Office Lav	S	1:38
157.2-13A	Fountain Outside 1st Floor Faculty Lavs	DF	1:40
157.2-13B	Fountain Outside 1st Floor Faculty Lavs	DFB	1:42

### Notes:

Please e-mail lab results to [labs@stohlenvironmental.com](mailto:labs@stohlenvironmental.com)

☒ If checked, also e-mail results to: [Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 4/30/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 5/5/2021

Received (Name / Lab): IC THARRIS DE SLAVER Date: 5.11.21 Time: 1:06pm

Sample Login (Name / Lab): Travis Bloom / Jhon Roca Date: 5/19/21 Time: 8:58 AM

Analysis (Name / Lab): Yang Oee Date: 5/28/21

QA/QC Review (Name / Lab): M. Miller Date: 6/1/21

Archived / Released:            QA/QC InterLAB Use:            Date:           

21-05-01484



Due Date:

06/08/2021

(Tuesday)

AE



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-157.2

Client: Lockport CSD

Contact: Tim Parker

Building: Emmet Belknap Intermediate School

Location: 491 High St, Lockport, NY 14094

## LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
157.2-14	1st Floor Faculty Ladies Lav	S	1:44
157.2-15	1st Floor Faculty Mens Lav Left	S	1:46
157.2-16	1st Floor Faculty Mens Lav Right	S	1:48
157.2-17	Fountains Outside Room 112 Left	DF	1:50
157.2-18	Fountains Outside Room 112 Right	DF	1:52
157.2-19	Boys Coach's Office Lav	S	1:54
157.2-20	Single Lav Outside Room B80	S	1:56
157.2-21	Classroom B80 Office Wash Sink	S	1:58
157.2-22	Home Ec B110 Left	S	2:00
157.2-23	Home Ec B110 Right	S	2:02
157.2-24	Home Ec B90 Left	S	2:04
157.2-25	Home Ec B90 Right	S	2:06
157.2-26	Home Ec B100 Left	S	2:08
157.2-27	Home Ec B100 Right	S	2:10
157.2-28	Boys Side Gym Fountain	DF	2:12
157.2-29	Girls Side Gym Fountain	DF	2:14
157.2-30A	Fountain Outside B30	DF	2:16
157.2-30B	Fountain Outside B30	DFB	2:18

## Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Chistine Schultz Print Name Stohl Env: Chistine Schultz Date: 4/30/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 5/5/2021

Received (Name / Lab): KTHARRIS K. Harris Date: 5.11.21 Time: 1:06 pm

Sample Login (Name / Lab): Traci Bloom / Jean Bloom Date: 5/19/20 Time: 9:01 AM

Analysis (Name / Lab): Gary Ode Date: 5/21/21 Time: 4:06 pm

QA/QC Review (Name / Lab): Memo Date: 6/11/21 Time: 4 pm

Archived / Released:                      QA/QC InterLAB Use:                      Date:                      Time:

