



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-05-01414

Received Date: 05/11/2021
Reported Date: 06/03/2021
Sampled By: Christine Schultz
Tech Certification #:

Project/Test Address: 2020L-157.10; Concession Stand; 491 High St; Lockport, NY 14094

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01414-001	157.10-1	04/30/2021	3 BAY SINK	1.13	06/02/2021	
21-05-01414-002	157.10-2	04/30/2021	MENS LAV	14.1	06/02/2021	
21-05-01414-003	157.10-3	04/30/2021	WOMENS LAV	20.2	06/02/2021	

Method: EPA 200.8
Analyst: Anthony Dee
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

