



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-05-01419

Received Date: 05/11/2021
Reported Date: 06/03/2021
Sampled By: Christine Schultz
Tech Certification #:

Project/Test Address: 2020L-157.11; Field House; 491 High St; Lockport, NY 14094

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01419-001	157.11-1	04/30/2021	COACH'S OFFICE	5.03	06/02/2021	
21-05-01419-002	157.11-2	04/30/2021	GIRLS LOCKER ROOM BUBBLER	<1.00	06/02/2021	
21-05-01419-003	157.11-3	04/30/2021	GIRLS LOCKER ROOM LEFT	2.30	06/02/2021	
21-05-01419-004	157.11-4	04/30/2021	GIRLS LOCKER ROOM CENTER	5.51	06/02/2021	
21-05-01419-005	157.11-5	04/30/2021	GIRLS LOCKER ROOM RIGHT	1.57	06/02/2021	
21-05-01419-006	157.11-6	04/30/2021	BOYS LOCKER ROOM LEFT	1.65	06/02/2021	
21-05-01419-007	157.11-7	04/30/2021	BOYS LOCKER ROOM CENTER	1.55	06/02/2021	
21-05-01419-008	157.11-8	04/30/2021	BOYS LOCKER ROOM RIGHT	1.87	06/02/2021	
21-05-01419-009	157.11-9	04/30/2021	BOYS LOCKER ROOM BUBBLER	1.20	06/02/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-05-01419

Project/Test Address: 2020L-157.11; Field House; 491 High St; Lockport, NY
14094

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Submitted to: (Lab Name) EHS

STOHL Job # 2020L-157.11

Client: Lockport CSD Contact: Tim Parker

Building: Field House Location: 491 High St, Lockport, NY 14094

LEAD


Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

21-05-01419



Due Date:
06/08/2021
(Tuesday)
AE

Please e-mail lab results to labs@stohlen.com ☒ If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 4/30/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 5/5/2021

Received (Name / Lab): RTA Harris Date: 5-11-21 Time: 11:34 Am

Sample Login (Name / Lab): Tracey Bloom / H&A Bloom Date: 5/19/21 Time: 8:31 AM

Analysis (Name / Lab): Gavin Doe Date: 6/24 Time: 7:30am

QA/QC Review (Name / Lab): Melinda Date: 6/3/21 Time: 10:00

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____