



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-05-01497

Received Date: 05/11/2021
Reported Date: 06/03/2021
Sampled By: Christin Schultz
Tech Certification #:

Project/Test Address: 2020L-157-4; Charles Upson Elementary; 28 Harding Ave; Lockport, NY 14094

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01497-001	157.4-1	04/27/2021	CLASSROOM 311 SINK	<1.00	06/02/2021	
21-05-01497-002	157.4-3	04/27/2021	CLASSROOM 309 SINK	<1.00	06/02/2021	
21-05-01497-003	157.4-5	04/27/2021	CLASSROOM 310 SINK	<1.00	06/02/2021	
21-05-01497-004	157.4-7	04/27/2021	CLASSROOM 307 SINK	<1.00	06/02/2021	
21-05-01497-005	157.4-9	04/27/2021	CLASSROOM 308 SINK	2.13	06/02/2021	
21-05-01497-006	157.4-11	04/27/2021	CLASSROOM 306 SINK	1.78	06/02/2021	
21-05-01497-007	157.4-13	04/27/2021	CLASSROOM 304 SINK	<1.00	06/02/2021	
21-05-01497-008	157.4-15	04/27/2021	CLASSROOM 305 SINK	1.86	06/02/2021	
21-05-01497-009	157.4-17	04/27/2021	ART ROOM 208 LEFT	1.08	06/02/2021	
21-05-01497-010	157.4-18	04/27/2021	ART ROOM 208 RIGHT	1.10	06/02/2021	
21-05-01497-011	157.4-19B	04/27/2021	FOUNTAIN OUTSIDE ART ROOM 208	<1.00	06/02/2021	
21-05-01497-012	157.4-20	04/27/2021	GYM OFFICE 204 A	1.02	06/02/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-05-01497

Project/Test Address: 2020L-157-4; Charles Upson Elementary; 28 Harding Ave; Lockport, NY 14094

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01497-013	157.4-21	04/27/2021	CLASSROOM 202 SINK	<1.00	06/02/2021	
21-05-01497-014	157.4-23	04/27/2021	CLASSROOM 116 SINK	<1.00	06/02/2021	
21-05-01497-015	157.4-25	04/27/2021	CLASSROOM 114 SINK	8.30	06/02/2021	
21-05-01497-016	157.4-27	04/27/2021	FACULTY ROOM 111 KITCHENETTE	<1.00	06/02/2021	
21-05-01497-017	157.4-28	04/27/2021	CLASSROOM 109 SINK	4.63	06/02/2021	
21-05-01497-018	157.4-30	04/27/2021	CLASSROOM 112 SINK	3.94	06/02/2021	
21-05-01497-019	157.4-32B	04/27/2021	FOUNTAIN OUTSIDE 105	<1.00	06/02/2021	
21-05-01497-020	157.4-33	04/27/2021	CLASSROOM 105 SINK	9.91	06/02/2021	
21-05-01497-021	157.4-35	04/27/2021	CLASSROOM 106 SINK	9.78	06/02/2021	
21-05-01497-022	157.4-37	04/27/2021	CLASSROOM 104 SINK	5.63	06/02/2021	
21-05-01497-023	157.4-39	04/27/2021	CLASSROOM 102 SINK	<1.00	06/02/2021	
21-05-01497-024	157.4-41	04/27/2021	CLASSROOM 512 SINK	<1.00	06/02/2021	
21-05-01497-025	157.4-43	04/27/2021	CLASSROOM 510 SINK	<1.00	06/02/2021	
21-05-01497-026	157.4-45	04/27/2021	CLASSROOM 508 SINK	<1.00	06/02/2021	
21-05-01497-027	157.4-47	04/27/2021	CLASSROOM 507 SINK	<1.00	06/02/2021	
21-05-01497-028	157.4-49	04/27/2021	CLASSROOM 506 SINK	<1.00	06/02/2021	
21-05-01497-029	157.4-51	04/27/2021	CLASSROOM 505 SINK	<1.00	06/02/2021	
21-05-01497-030	157.4-53	04/27/2021	CLASSROOM 504 SINK	<1.00	06/02/2021	
21-05-01497-031	157.4-55	04/27/2021	CLASSROOM 503 SINK	<1.00	06/02/2021	
21-05-01497-032	157.4-57	04/27/2021	CLASSROOM 502 SINK	<1.00	06/02/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-05-01497

Project/Test Address: 2020L-157-4; Charles Upson Elementary; 28 Harding Ave; Lockport, NY 14094

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-05-01497-033	157.4-59	04/27/2021	CLASSROOM 501 SINK	<1.00	06/02/2021	
21-05-01497-034	157.4-61	04/27/2021	NURSE STUDENT LAV	<1.00	06/02/2021	
21-05-01497-035	157.4-62	04/27/2021	NURSE STAFF LAV	<1.00	06/02/2021	
21-05-01497-036	157.4-63	04/27/2021	NURSE MAIN SINK	1.22	06/02/2021	
21-05-01497-037	157.4-64	04/27/2021	TEACHER'S WORK ROOM SINK	<1.00	06/02/2021	
21-05-01497-038	157.4-65	04/27/2021	INSTRUMENTAL MUSIC 407	1.05	06/02/2021	
21-05-01497-039	157.4-66	04/27/2021	VOCAL MUSIC 406	<1.00	06/02/2021	
21-05-01497-040	157.4-67B	04/27/2021	CAFETERIA FOUNTAIN	<1.00	06/02/2021	
21-05-01497-041	157.4-68	04/27/2021	FACULTY DINING ROOM 402	<1.00	06/02/2021	
21-05-01497-042	157.4-69	04/27/2021	KITCHEN SANITIZER SINK	<1.00	06/02/2021	
21-05-01497-043	157.4-70	04/27/2021	KITCHEN KETTLE FILL	<1.00	06/02/2021	
21-05-01497-044	157.4-71	04/27/2021	KITCHEN PREP SINK	<1.00	06/02/2021	

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-157.4

Client: Lockport CSD

Contact: Tim Parker

Building: Charles Upson Elementary

Location: 28 Harding Ave, Lockport, NY 14094

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
157.4-1	Classroom 311 Sink	S	23:48
157.4-3	Classroom 309 Sink	S	23:50
157.4-5	Classroom 310 Sink	S	23:52
157.4-7	Classroom 307 Sink	S	23:54
157.4-9	Classroom 308 Sink	S	23:56
157.4-11	Classroom 306 Sink	S	23:58
157.4-13	Classroom 304 Sink	S	0:00
157.4-15	Classroom 305 Sink	S	0:02
157.4-17	Art Room 208 Left	S	0:04
157.4-18	Art Room 208 Right	S	0:06
157.4-19B	Fountain Outside Art Room 208	DFB	0:08
157.4-20	Gym Office 204A	S	0:10
157.4-21	Classroom 202 Sink	S	0:12
157.4-23	Classroom 116 Sink	S	0:14
157.4-25	Classroom 114 Sink	S	0:16
157.4-27	Faculty Room 111 Kitchenette	S	0:18
157.4-28	Classroom 109 Sink	S	0:20
157.4-30	Classroom 112 Sink	S	0:22

Notes:

Please e-mail lab results to labs@stohlenvironment.com

☒ If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 4/27/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 5/4/2021

Received (Name / Lab): KTHARRIS K. HARRIS Date: 5/11 Time:

Sample Login (Name / Lab): Trace Bloom / Lisa Boon Date: 5/19/21 8:42 AM

Analysis (Name / Lab): Young Orel Date: 6/16/21 5:04 PM

QA/QC Review (Name / Lab): melele Date: 6/13/21 km

Archived / Released: QA/QC InterLAB Use: Date:

21-05-01497



Due Date:
06/08/2021
(Tuesday)
AE



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-157.4

Client: Lockport CSD

Contact: Tim Parker

Building: Charles Upson Elementary

Location: 28 Harding Ave, Lockport, NY 14094

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
157.4-32B	Fountain Outside 105	DFB	0:24
157.4-33	Classroom 105 Sink	S	0:26
157.4-35	Classroom 106 Sink	S	0:28
157.4-37	Classroom 104 Sink	S	0:30
157.4-39	Classroom 102 Sink	S	0:32
157.4-41	Classroom 512 Sink	S	0:34
157.4-43	Classroom 510 Sink	S	0:36
157.4-45	Classroom 508 Sink	S	0:38
157.4-47	Classroom 507 Sink	S	0:40
157.4-49	Classroom 506 Sink	S	0:42
157.4-51	Classroom 505 Sink	S	0:44
157.4-53	Classroom 504 Sink	S	0:46
157.4-55	Classroom 503 Sink	S	0:48
157.4-57	Classroom 502 Sink	S	0:50
157.4-59	Classroom 501 Sink	S	0:52
157.4-61	Nurse Student Lav	S	0:54
157.4-62	Nurse Staff Lav	S	0:56
157.4-63	Nurse Main Sink	S	0:58

Notes:

Please e-mail lab results to labs@stohlenv.com

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 4/27/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 5/4/2021

Received (Name / Lab): KTHARRIS R. HARRIS Date: 5-4-21 Time: 1:24pm

Sample Login (Name / Lab): Traci Bloom / Fran Bloom Date: 5/19/21 Time: 8:45 AM

Analysis (Name / Lab): Young Deen Date: 6/2/21 Time: 5:04 pm

QA/QC Review (Name / Lab): Muhle Date: 6/3/21 Time: noon

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



STOHL Job # 2020L-157.4

Building: Charles Upson Elementary Location: 28 Harding Ave, Lockport, NY 14094

Turnaround

X

20 Days

Ehenderson@StohlEnv.com

Archived / Released: QA/QC InterLAB Use: Date: Time: